


INSULATED CANTED ROOF CURB NON-PROPELLER PRODUCTS



(1)

OPTIONS:

- 1. Damper Shelf.
- 2. Metal Liner solid or screen type.
- 3. Burglar bars 1/2" dia. on 6" centers.
- 4. Finishes baked or air-dried enamel or epoxy.
- 5. Heights: 8, 12, 16, 18, 20, 24" or special heights.
- 6. Single pitch or double pitch.
- 7. Aluminum construction.
- 8. Standard curb is "RF" roof over type. ("SF" available upon request)

FAN	"/	A" OD (So	quare) CUI	RB		DB	"B"	"C"	
SIZE	ТХВ	TXD	RCXII	RED / LPD	FAN SIZE	CURB OD "A"	CURB HEIGHT	WOOD NAILER	
6	-	14-3/4	14-3/4	14-3/4	6	14-3/4			1. Damper shelf opening to be 1" less than damper size. Shelf must be specified if
8	14-3/4	14-3/4	14-3/4	14-3/4	8	14-3/4			required.
10	14-3/4	14-3/4	22-1/4	14-3/4	9	14-3/4]		2. All curbs are 18 gauge G-90 galvanized steel with continuous seams.
12	22-1/4	22-1/4	22-1/4	22-1/4	11	22-1/4			3. See current curb submittal for all propeller
14			22-1/4				1		fan roof curbs.
15	22-1/4	22-1/4	-	22-1/4	12	22-1/4	1		
16			22-1/4				1		
18	27-3/4	-	27-3/4	-	14	22-1/4	12"	1-1/2"	
20	-	-	27-3/4	-	16	22-1/4	STD	Sq	
24	33-3/4	-	33-3/4	-	18	27-3/4	1		
26	-	-	33-3/4	-	20	27-3/4	1		
30	40-3/4	-	40-3/4	-	24	33-3/4	1		
33	-	-	40-3/4	-	30	40-3/4	1		
36	40-3/4	-	40-3/4	-	36	40-3/4			
42	53-1/4	-	-	-	42	53-1/4			Curb O.D. (A Dimension) Less 3.25 inches
48	53-1/4	-	-	-	48	53-1/4	1		

ACCESSORY ITEM	S 1	2	3	4	5	ACCESSORY ITEMS	1	2	3	4	5
Project: Customer:						Subn	nitte	d:			
Customer:						Appr	ove	d:			
Location:						••					





TYPE SF SELF-FLASHING CURB



STANDARD FEATURES

- Constructed of 18 ga. galv. steel with continuous welded seams and integral base plate for water tightness and extra strength.
- Wide base flashing to insure adequate bond to roofing surface for water tight seal to roof.
- Lined with 1-1/2" fire proof sound attenuating thermal insulation.
- Top of curb covered with 1/4" polystyrene gasket for weather seal and to reduce metal to metal conducted noise.





OPTIONS

- Constructed of .063" aluminum.
- Interior metal liner.
- Standard heights of 12, 14, 16, 18, 20, 24", or any special height.
- Damper shelf standard or custom size opening.
- Wide flange (6" or 8" wide).
- Backdraft damper.
- Protective or decorative coatings.
- Heavy-gauge construction.


	S	PECIFICATI	ONS ANI		ISIONS		
REFERENCE	QUANTITY	GALV. OR ALUM.	к	Ν	М	н	OPTIONS





STANDARD FEATURES

• Heavy-gauge aluminum construction with continuous welded seams for water tightness and extra strength.



PROJECT LOCATION ARCHITECT ENGINEER CONTRACTOR SUBMITTED BY DATE P.O. NO.


K - MEASUREMENT

1/4" LESS THAN FAN BASE

J - MEASUREMENT

1" LARGER THAN EXISTING CURB O.D.


	SPE	CIFICATI	ONS AN	D DIMENSIONS
REFERENCE	QUANTITY	К	J	OPTIONS





CURB HINGE ACCESSORY





ITEM #	PART #	DESCRIPTION	QTY	ITEM #	PART #	DESCRIPTION	QTY
1	634012	3/8" Flat Washer	2	6	90005802	Hinge Bracket Left Half	1
2	634025	3/8-16 Loknut	2	7	90005101	Curb Hinge Bracket Right	1
3	603656	3/8 x 1-1/4" Long Spacer	2	8	634002	5/16-18 x 3/4 Hex Bolt	16
4	634138	3/8-16 x 2" Long Bolt	4	9	634027	5/16-18 Flange Nut	16
5	90005702	Hinge Bracket Right Half	1	10	90005201	Curb Hinge Bracket Left*	1
*Items or	n opposite s	ide, not shown	~	11	634028	13/8-16 Flange Nut	2

Note: Curb cap needs to be $\frac{1}{2}$ " minimum larger than the roof curb or roof curb adaptor to allow for bolt head clearance and curb cap tilting around the roof curb or roof curb adaptor.

- 1. With fan in place on roof curb, locate the hinge cap on both end, mark the holes for 5/16" diameter bolts, drill (8) 11/32" diameter holes at the marked locations.
- 2. Attach the hinge cap (items 6 & 7) to curb cap or fan using (8) 5/16" bolts & flanged nuts, locate bolt head on the inside of the curb cap.
- 3. With unit in place on roof curb, align curb hinge on roof curb or curb cap adaptor as shown and mark the (8) locations in the roof curb or curb adaptor**.
- 4. Drill (8) 11/32" diameter holes in previously marked hole locations.
- 5. Attach curb hinge to roof curb using (8) 5/16" diameter bolts.
- 6. You can now tilt the fan open about 60°, use the 3/8" bolt to lock the fan in place and prevent it from tipping or slamming shut.
- 7. Remove the locking bolt when closing back the fan in place, store the bolt next to the fan for future openings or locks.


CAUTION: Make sure to remove grease box (if applicable) when tilting the fan to prevent any spillage.

** Two hinge pivot holes are provided in the curb hinge to allow the curb hinge to be mounted higher or lower on the roof curb as required.




BACKDRAFT DAMPER FOR ROOF MOUNTED AND INLINE **CENTRIFUGAL/PROPELLER EXHAUST FANS**









CAUTION: Motor kits are not suitable for use in explosive or flammable areas or airflows.

OPTIONAL MOTOR KIT 2 ŝ

For low velocity (CFM) field adjustment of spring tension may be required to ensure that damper blades open completely.

	CENTRIFUGAL ROOF FANS	INLINE FANS						PROPELLER		~		· .	hole	\$	4				
FAN	DB, RED, TXB, LPD, TXD		SQ	В		SQ	D	ARE	t mei				ment	AIR FLOW					
SIZE	"A" SQUARE		"A" SQUARE		5	"A" SQUARE		"A" SQUARE		<u> </u>	ſ	:	spring tension adjustment holes						
6	11		-			9		-		4	ß	. ام	ensio						
7	-		12			-		-		- ~		· ·	ng te						
8	11		12		12		12		12 12			-					Spri		
9	11	-			-		-		╼┍┙╼┍┙ ╼┍┙╼┍╴╗										
10	11		14			14		14		∞ ≥ 1									
11/12	18		18			18		18	STANDARD SPECIFICATIONS:										
14	18		-			-		-	Maximum Face Velocity: 2250 fpm. Dimensions: See sizing chart "A" Dimension is square damper size. Frame: Galvanized steel, 2" Deep										
15	18		22			20		-											
16	18		-			-		22	Blades: 26 gauge Mill Finish aluminum. Blade pivots: Stainless steel rivet at all pivot points.										
18	24		24			-		-	Seals: Felt between adjacent blades. Counter Balance: Adjustable spring tension. Finish: Mill. Max Temp: Damper 250° F Motor 130° F										
20	24	28					26												
24	30	35			-		-	Motor 130° F CAUTION: Motor kits are not suitable for use in exp sive or flammable areas or airflows.					plo-						
30	36	40						-	sive or flammat	ble areas	or air	flows.							
36	36	48				-		-	NOTES: (1) Units are u	ndersized	1/4"	to fit in	square	e ducts.					
42	48	54				-		-	(2) Do not mount fan less than 1/3 diameter of the fan fro the damper.						an fron				
48	48	-				-		-	(3) Dampers shipped in individual cartons.(4) Motor kits ship loose for field installation.										
AC	CESSORY ITEMS	1	2	3	4	5		ACCESSORY	ITEMS		1	2	3	4	5				
Project	·							, c	Submitted	۲. ۲									
Custom	ner:							A	Approved										
Locatio	n:									-									

